



2025 CHC Project Review

Richard Williams
Cube Hydro Carolinas, LLC

Streamflow 2025

QTR	Actual(cfs)	20 year avg(cfs)	Percentage of 20 year average
1	4,360	5,852	75%
2	3,817	4,490	85%
3	2,689	2,937	92%
4	1,896	4,038	47%
2025	3,182	4,320	74%

Summary

- CHC Yadkin project did not enter low inflow protocol in 2025.
- CHC Yadkin did not have a rule curve deviation in 2025.
- Fish spawn enhancement period completed within spawning limits.
- No violations of minimum streamflow.

2026 System Summary

- January - April Inflow totals for 2026 have averaged 46 % of median based on 20-year averages.
- Fish spawn enhancement started April 15th
- Daily minimum average stream flow totals have been met.
- No rule curve deviations during 2026
- Current Elevation data is available on our web-site. Search [Lake Levels – Cube Hydro Carolinas](#)

Questions??

Richard Williams

Richard.Williams@eaglecreekre.com